

---

**SECTION 12 36 00**  
**PORCELAIN COUNTERTOPS**

---

Corian® Endura™ high-performance porcelain manufactured by DuPont, (DuPont Specialty Products USA, LLC), Experimental Station 356, 200 Powder Mill Road, Wilmington, DE 19803, Toll-Free: (800) 426-7426, Web site: [www.endura.corian.com](http://www.endura.corian.com); [www-surfaces.dupont.com](http://www-surfaces.dupont.com)

*Note: The purpose of this product guide specification is to assist the Specifier in specifying Corian® Endura™. Refer to Corian® Design (800-426-7426) and/or Corian® Endura™ Technical Bulletins for additional information. Use this guide specification for interfacing with architectural millwork and/or trim components.*

*Design Professionals or Architects need to review Sections and edit to fit the needs of the project and local building code(s). Throughout the guide specification, there are Specifier Notes in blue to assist in the editing of the file. Optional user input areas are enclosed within brackets, [ \_\_\_\_\_ ]; delete optional text in the final copy of specification.*

*This product guide specification is written in accordance with the Construction Specifications Institute (CSI) current Masterformat® 2020 CSI Divisions, SectionFormat™ and PageFormat™. References are in accordance with Masterformat®. The Specifier needs to coordinate numbers and titles with sections included for the project.*

---

**PART 1 - GENERAL**

---

<sup>1</sup>Qualified construction and design professionals may copy this document for the purpose of creating construction specifications or purchase orders for products and materials manufactured by DuPont Specialty Products USA, LLC. Masterformat®, Sectionformat- and Pageformat- are trademarks or registered trademarks of Construction Specifications Institute and Construction Specifications Canada. LEED® is a registered trademark of US Green Building Council. NFPA 101® and Life Safety Code® are registered trademarks of the National Fire Protection Association, Inc.

© 2021 DuPont. DuPont™, the DuPont Oval Logo, Corian®, the Corian® logo system, Endura™, and all trademarks and service marks denoted with ™, SM or ® are trademarks or registered trademarks of affiliates of DuPont de Nemours, Inc. unless otherwise noted.

**1.01 SUMMARY**

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 01 Specification Sections, apply to this Section.

**1.02 SUMMARY**

- A. This Section includes, but is not limited to, the following horizontal HIGH-PERFORMANCE PORCELAIN (ALSO KNOWN AS ULTRACOMPACT, SINTERED) surfacing product types:
  - 1. Countertops.
  - 2. Countertops with integrated sinks and lavatory bowls.
  - 3. Countertops with undermount sinks and lavatory bowls.
  - 4. Countertops with drop-in sinks and lavatory bowls.
  - 5. Exterior countertops.
  - 6. Exterior countertops with [integrated, undermount, drop-in][sinks]
  - 7. Reception areas.
  - 8. Nurses stations.
  - 9. Vanity tops.
  - 10. Tabletops.
  - 11. Bar tops.
  - 12. Cold cafeteria surfaces.
  - 13. Hot cafeteria surfaces.
  - 14. [\_\_\_\_\_].
  - 15. Other interior/exterior counter or surfacing applications as shown on drawings.

**1.03 RELATED REQUIREMENTS**

- A. Section 01 81 13 – Sustainable Design Requirements for additional LEED requirements.
- B. Section 06 10 00 – Rough Carpentry.
- C. Section 06 61 13 – Simulated Stone Fabrications.
- D. Section 06 61 16 – Solid Surfacing Fabrications.
- E. Section 07 92 00 – Joint Sealants.
- F. Section 09 28 13 – Cementitious Backing Boards.
- G. Section 09 30 13.13 – Porcelain Tiling.
- H. Section 11 42 16 – Food Preparation Surfaces.
- I. Section 12 30 00 – Casework.
- J. Section 12 36 00 – Countertops.
- K. Section 12 36 61 – Simulated Stone Countertops.
- L. Section 12 36 61.16 – Solid Surfacing Countertops.
- M. Section 12 36 61.19 – Quartz Agglomerate Countertops.
- N. Section 22 01 00 – Plumbing.
- O. Section 26 50 00 – Lighting.

**1.04 REFERENCES**

- 
- A. ISO 10545 Ceramic tiles – Part 3: Determination of water absorption, apparent porosity, apparent relative density and bulk density.
  - B. ISO 10545 Ceramic tiles – Part 13: Determination of chemical resistance.
  - C. ISO 10545 Ceramic tiles – Part 12: Determination of frost resistance.
  - D. EN 15186 Furniture – Assessment of the surface resistance to scratching.
  - E. ISO 10545 Ceramic tiles – Part 10: Determination of moisture expansion.
  - F. ISO 10545 Ceramic tiles – Part 4: Determination of modulus of rupture and breaking strength.
  - G. ASTM C170M-16 – Standard Test Method for Compressive Strength of Dimension Stone.
  - H. EN 14617-9 – Agglomerated stone – Test Methods – Part 9: Determination of impact resistance.
  - I. ASTM E136 – Standard Test Method for Behavior of Materials in a Vertical Tube Furnace at 750 °C.
  - J. UL (Underwriters Laboratories) – ANSI/UL 723 – Standard Test Method for Surface Burning Characteristics of Building Materials.
  - K. ULC (Underwriters Laboratories of Canada) – ULC/CAN-S102 – Standard Method of Test for Surface Burning Characteristics of Building Materials and Assemblies.
  - L. ASTM C372 – Standard Test Method for Linear Thermal Expansion of Porcelain Enamel and Glaze Frits and Fired Ceramic Whiteware Products by the Dilameter Method.
  - M. ASTM C424 – Standard Test Method for Craziing Resistance of Fired Glazed Whitewares by Autoclave Treatment.
  - N. ASTM C650 – Standard Test Method for Determination of Resistance to Chemical Substances.
  - O. ASTM C482 – Standard Test Method for Bond Strength of Ceramic Tile to Portland Cement.
  - P. ASTM C1027 – Standard Test Method for Determining Visible Abrasion Resistance of Glazed Ceramic Tile.
  - Q. ASTM C1243 – Standard Test Method for Relative Resistance to Deep Abrasive Wear of Unglazed Ceramic Tile by Rotating Disc.
  - R. ASTM C1378 – Standard Test Method for Resistance to Staining.
  - S. ISO 13007 – Ceramic Tiles - Grouts And Adhesives.
  - T. ANSI 118.15 – Improved Method Dry-Set Cement Mortar.
  - U. UL Environment/GREENGUARD - UL 2818 – Certification Standard for Chemical Emissions for Building Materials, Finishes and Furnishings, Section 7.1.
  - V. UL Environment/GREENGUARD - UL 2818 – Gold Certification Standard for Chemical Emissions for Building Materials, Finishes and Furnishings, Section 7.1 and 7.2.
  - W. UL 2824 – GREENGUARD Certification Program Method for Measuring Microbial Resistance from Various Sources Using Static Environmental Chambers.
  - X. SCAQMD (South Coast Air Quality Management District) VOC (Volatile Organic Content) Rule 1168 for Adhesive and Sealant Applications.
  - Y. Star-K Kosher Certification ([www.star-k.org](http://www.star-k.org)).

#### **1.05 SUBMITTALS**

- A. Submit product data for each type of product indicated.

1. Submit manufacturer's product data on material characteristics, performance properties, fabrication instructions, installation instructions and maintenance instructions.
- B. Shop drawings:
  1. Show location of each item; provide complete detailed and dimensioned plans and elevations, large-scale details, attachment devices and other components.
  2. Show the following:
    - a. Full-size details, edge details, attachments, etc.
    - b. Locations and sizes of furring, blocking, including concealed blocking and reinforcement specified in other Sections.
    - c. Fabrication details for brackets.
    - d. Locations and sizes of cutouts and holes for plumbing fixtures, faucets, soap dispensers, waste receptacles and other items installed in porcelain surface.
    - e. Locations and sizes of cutouts for sink installation and lavatory installation. Type of sealant.
    - f. Type of grout.
    - g. Seam locations.
- C. Samples:
  1. For each type of product indicated:
    - a. Submit minimum 40-mm-by-40-mm (2.4-inch-by-2.4-inch) sample in specified color and finish. For viewing pattern or veining, submit minimum 225-mm-by-110-mm (8.9-inch-by-4.3-inch) sample.
    - b. Cut sample and seam together for representation of seaming techniques.
    - c. Indicate full range of color and pattern variation.
    - d. Approved samples will be retained as a standard for work.
- D. Product data:
  1. Indicate product description, fabrication information and compliance with specified performance requirements.
- E. Sustainable Design Reporting:
  1. Provide documentation from manufacturer indicating that adhesives applied on project site meet or exceed emissions guidelines for volatile organic compounds (VOCs) of SCAQMD Rule #1168 and Bay Area Quality Management District (BAAQMD).
- F. LEED Submittals:
  1. LEED® 2009, Credits MR Credit 4.1– Low-Emitting Materials – Adhesives and Sealants,
    - a. Provide documentation from manufacturers indicating that adhesives and sealants applied on project site meet or exceed emissions guidelines for volatile organic compounds (VOCs) and comply with SCAQMD Rule #1168 and Bay Area Quality Management District (BAAQMD).
  2. LEED® NC v4, EQ: Indoor Environmental Quality, EQ Credit: Low-Emitting Materials.
    - a. Provide documentation from manufacturers that products meet or exceed emissions guidelines for volatile organic compounds (VOCs).

- b. Provide documentation from manufacturers that adhesives and sealants meet or exceed emissions guidelines for volatile organic compounds (VOCs) and comply with SCAQMD Rule #1168 and Bay Area Quality Management District (BAAQMD).
- 3. LEED® NC v4, MR Credit: Building Product Disclosure and Optimization - Material Ingredients.
  - a. Option 1. Material Ingredient Reporting.
    - 1) Provide manufacturer's HPD (Health Product Declaration).
- G. Fabricator/installer qualifications:
  - 1. Provide copy of certification information/qualifications.
- H. Certificates: Certify that products meet or exceed requirements.
  - 1. UL Environment – GREENGUARD and GREENGUARD Gold, current low emitting VOC certification of porcelain surface, quartz surface and solid surface products in accordance with UL 2818.
  - 2. UL Environment – GREENGUARD and GREENGUARD Gold, current low emitting VOC certification for manufacturer's recommended adhesive and/or sealant in accordance with UL 2824.
  - 3. UL Environment – Mold Resistance Certification in accordance with UL 2824.
- I. Fire test response characteristics:
  - 1. United States – Provide non-combustible characteristics as determined by testing product per ASTM E136.
  - 2. Canada – Provide non-combustible characteristics as determined by testing product per ASTM E136.
- J. Maintenance data:
  - 1. Submit manufacturer's care and maintenance data.
  - 2. Include in project closeout documents.

**1.06 QUALITY ASSURANCE**

- A. Fabricator and installer qualifications:
  - 1. Work shall be done by Certified fabricators who have been trained and certified by manufacturer's designated Distributors on how to fabricate, transport, handle and install product.
  - 2. Standalone commercial installation shall be done by approved commercial installers. Commercial installers are approved by manufacturer's designated Distributors.
- B. Allowable tolerances:
  - 1. Variation in component size: 3 mm (±1/8 inch) in 10-foot length direction.
  - 2. Location of openings: 3 mm (±1/8 inch) from indicated location.
  - 3. Minimum of 3 mm (1/8 inch) clearance between porcelain surfaces and each wall.
- C. Coordination drawings:
  - 1. Shall be prepared indicating:
    - a. Plumbing work.
    - b. Electrical work.
    - c. Miscellaneous steel for the general work.

- d. Indicate location of all walls (rated and non-rated), blocking locations and recessed wall items, etc.
- 2. Content:
  - a. Project-specific information, drawn accurately to scale.
  - b. Do not base coordination drawings on reproductions of the contract documents or standard printed data.
  - c. Indicate dimensions shown on the contract drawings and make specific note of dimensions that appear to be in conflict with submitted equipment and minimum clearance requirements.
  - d. Provide alternate sketches to designer for resolution of such conflicts.
    - 1) Minor dimension changes and difficult installations will not be considered changes to the contract.
- 3. Drawings shall:
  - a. Be produced in 1/2-inch scale for all fabricated items.
- 4. Drawings must be complete and submitted to the architect within 60 days after award of contract for record only.
  - a. No review or approval will be forthcoming.
  - b. Coordination drawings are required for the benefit of contractor's fabricators/installers as an aid to coordination of their work to eliminate or reduce conflicts that may arise during the installation of their work.
- D. Job mock-up:
  - 1. Prior to fabrication of architectural millwork, erect sample unit to further verify selections made under sample submittals and to demonstrate the quality of materials and execution.
  - 2. Mock-up shall be [\_\_\_\_\_] feet wide, full depth [with splash]. Include [plumbing fixtures and trim.] [\_\_\_\_\_].
  - 3. Build the mock-up to comply with the contract documents and install in a location as directed by the architect. Locate [\_\_\_\_\_].
  - 4. Notify the architect two weeks in advance of the date of when the mock-up will be delivered.
  - 5. Should mock-up not be approved, re-fabricate and reinstall until approval is secured.
  - 6. Remove rejected units from project site.
  - 7. Mock-up, once approved, may become a part of the project and serve as a standard for judging quality of all completed units of work.
- E. Pre-installation conference:
  - 1. Conduct conference at project site to comply with requirements in Division 1.

**1.07 DELIVERY, STORAGE AND HANDLING**

- A. Deliver no components to project site until areas are ready for installation.
- B. Store components indoors in clean and dry area prior to installation.
- C. Handle materials to prevent damage to finished surfaces.
- D. Follow manufacturer's safe handling and storage recommendations.

- E. Provide protective coverings to prevent physical damage or staining following installation for duration of project.

**1.08 WARRANTY**

- A. Provide manufacturer’s 10-year product only warranty.

**1.09 MAINTENANCE**

- A. Provide care and maintenance requirements as specified by the manufacturer.

**PART 2 - PRODUCTS**

**2.01 MANUFACTURERS**

- A. Contract Documents are based on high performance porcelain also known as ultra-compact, sintered [slab, panel or sheet] products manufactured by DuPont (DuPont Specialty Products USA, LLC). Provide Corian® Endura™ (basis of design) subject to compliance with the requirements.
  - 1. Corian® Design, Corian® Endura™
    - a. Address:, 974 Centre Road, Wilmington, DE 19805.
    - b. Phone: (800) 426-7426.
    - c. Website: [www-surfaces.dupont.com](http://www-surfaces.dupont.com); [www.endura.corian.com](http://www.endura.corian.com)
    - d. Subject to compliance with the requirements, provide the following product: high-performance porcelain surface from Corian® Design (basis of design).
- B. Substitutions: Not permitted.

**2.02 MATERIALS**

- A. Material:
  - 1. Corian® Endura™ high-performance porcelain, also known as ultra-compact, sintered surfacing material. Corian® Endura™ high-performance porcelain is comprised of natural minerals and pigments sintered under high pressure into slabs, sheets or panels.
  - 2. Material shall have minimum physical and performance properties as specified.
  - 3. Color Portfolio [\_\_\_\_\_], Color [\_\_\_\_\_], Finish [\_\_\_\_\_].
- B. Thickness:
  - 1. 12 mm (1/2 inch).
  - 2. 20 mm (3/4 inch).
- C. Edge treatment:
  - 1. Exposed Edge:
    - a. [\_\_\_\_\_].
    - b. [\_\_\_\_\_].
    - c. [\_\_\_\_\_].
    - d. As indicated.
  - 2. Appliance Edge.
    - a. Finished.

- b. Not Finished.
- D. Seam width:
  - 1. Exterior countertops: 3 mm (1/8 inch) nominal Silicone adhesive to allow for expansion with the edges of porcelain surface having a 2 mm (3/32 inch) chamfer.
  - 2. For interior countertop rigid seams, with or without bevel, use commercial Joint Adhesive for porcelain surfaces or manufacturers recommended Joint Adhesive (Corian® Joint Adhesive).
  - 3. 2 mm (3/32 inch) bevel provides a durable edge for handling and this will create a slightly wider seam with Silicone adhesive or commercial Joint Adhesive for porcelain surfaces or manufacturers recommended Joint Adhesive (Corian® Joint Adhesive).
- E. Sink mounting:
  - 1. Integrated.
  - 2. Undermount.
  - 3. Drop in.
- F. Backsplash:
  - 1. Applied.
- G. Endsplash:
  - 1. Applied.
- H. Corian® Endura™ Performance Properties (TYPICAL RESULTS):
 

1. % Water Absorption	0.08% (Average)	ISO 10545-3
2. Resistance to Low Concentrations of Acids and Bases	ULA-ULB (Satin/Mineral)	ISO 10545-13
3. Frost Resistance	Resistant	ISO 15045-12
4. Scratch Resistance	Class A	ISO 15186 met. B
5. Moisture Expansion	0.01% (0.1 mm)	ISO 15045-10
6. Breaking Strength	5,500 N Average (12 mm)	ISO 10545-4
7. Breaking Strength	14,400 N Average (20 mm)	ISO 10545-4
8. N/mm <sup>2</sup> Flexural Strength	53 N/mm <sup>2</sup> Average (12 mm)	ISO 10545-4
9. N/mm <sup>2</sup> Flexural Strength	52 N/mm <sup>2</sup> Average (20 mm)	ISO 10545-4
10. Compression Strength	527.9 Mpa	ASTM C170M-16
11. Impact Resistance	3.03 J (12 mm)	EN 14617-9
12. Non-combustible	PASS	ASTM E136
13. Flammability	Class A, All Colors	NFPA 101® Life Safety Code
14. Flame Spread Index	0 (12mm)	ANSI/UL 723
15. Smoke Developed Index	0 (12mm)	ANSI/UL 723
16. Flame Spread Value	0 (12 mm)	CAN/ULC-S102
17. Smoke Developed Value	0 (12 mm)	CAN/ULC-S102
18. Linear Thermal Expansion	6.23 x 10 <sup>-6</sup> /°C (avg. over -20° to 80°C) 3.46 x 10 <sup>-6</sup> /°F (avg. over -4° to 176°F)	ASTM C372
19. Craze Resistance,	No Craze Observed	ASTM C424
20. Chemical Substances Resistance	No Effect	ASTM C650-2



- 21. Mohs Scratch Hardness 7 ASTM C1895
- 22. Moisture Expansion 0.007% Average ASTM C370-12
- 23. Bond Strength of Ceramic Tile to Portland Cement  
200 PSI ASTM C482-02
- 24. Visual Abrasion Resistance 150 Rev. Visible difference ASTM C1027-19
- 25. Deep Abrasive wear by Rotating Disc  
Average Volume 53.4 mm<sup>3</sup> ASTM C1243-93
- 26. Resistance to Staining No Visual Effect ASTM C1378-20
- 27. Nominal Thickness 12 mm and 20 mm
- 28. Nominal Weight per square foot for 12 mm thickness is 6 pounds
- 29. Nominal Weight per square foot for 20 mm thickness is 10 pounds
- I. CORIAN® ENDURA™ CERTIFICATIONS and APPROVALS:
  - 1. UL 2818 UL Environment/GREENGUARD Certified.
  - 2. UL 2818 UL Environment/GREENGUARD Gold Certified.
  - 3. UL 2824 - Mold Resistant.
  - 4. Kosher, Listed by Star-K.

**2.03 ACCESSORY PRODUCTS**

- A. Mounting Adhesives:
  - 1. 100% silicone adhesive.
  - 2. Use commercial adhesive designed for bonding porcelain/ceramic tile to substrates. If exterior use adhesive designed for bonding porcelain/ceramic tile to substrates and is suitable for range of outdoor conditions.
- B. Seam Adhesive:
  - 1. Corian® Joint Adhesive to create color-coordinated rigid seam.
  - 2. Use commercial Joint Adhesive designed for porcelain surfaces or manufacturers recommended Joint Adhesive (Corian® Joint Adhesive) to create rigid seams.
  - 3. 100% silicone adhesive for flexible seam.
- C. Sink/bowl mounting hardware:
  - 1. Manufacturer’s approved sink setters, bowl clips and fasteners for attachment of undermount sinks/bowls.

**2.04 FABRICATION**

- A. Fabricate components to greatest extent practical to sizes and shapes indicated, in accordance with approved shop drawings and manufacturer’s printed instructions and technical bulletins.
- B. Form joints between components using manufacturer’s standard joint adhesive (Corian® Joint Adhesive).
  - a. Reinforce as required.
  - 2. Provide factory cutouts for plumbing fittings and bath accessories as indicated on the drawings.
  - 3. Rout and finish component edges with clean, sharp returns.
  - 4. Rout cutouts, radii and contours to template.

C. Smooth edges.

**2.05 FINISHES**

- A. Select from the manufacturer's standard color chart.
  - 1. Portfolio: [\_\_\_\_], Color: [\_\_\_\_], Finish:[\_\_\_\_]

**PART 3 - EXECUTION**

**3.01 INSTALLATION**

- A. General
  - 1. Install countertop materials in accordance with manufacturer's instructions.
  - 2. Additional weight from attached sink or lavatory will affect maneuverability of tops during transportation and installation.
  - 3. Carefully plan work to avoid damaging finished tops during transportation and installation.
- B. Install components plumb and level, in accordance with approved shop drawings and product installation details.
  - 1. Tops:
    - a. Flat and true to within 3 mm (1/8 inch) of a flat surface over a 10-foot length.
    - b. Allow a minimum of 3 mm (1/8 inch) clearance between surface and each wall.
    - c. Form field joints using manufacturer's recommended Joint Adhesive (Corian® Joint Adhesive), with joint widths <3 mm (<1/8 inch) in finished work.
    - d. Keep components and hands clean when making joints.
- C. Sinks/Lavatory Bowls:
  - 1. Adhere undermount sinks/lavatory bowls to countertops using manufacturer's recommended adhesive and mounting hardware.
  - 2. Adhere drop-in sinks/bowls to countertops using silicone sealant/adhesive and manufacturer-recommended adhesives.
- D. Provide backsplashes and endsplashes as indicated on the drawings.
  - 1. Adhere to countertops using silicone adhesive.
    - a. Keep components and hands clean when working with silicone adhesive.

**3.02 CONNECTIONS:**

- A. Make plumbing connections in accordance with Division 22.
- B. Make electrical connections in accordance with Division 26.

**3.03 CLEANING AND PROTECTION**

- A. Keep components and hands clean during installation.
- B. Remove adhesives, sealants and other stains in accordance with manufacturer's instructions.
  - 1. Clean exposed surfaces in accordance with manufacturer's instructions.
  - 2. Components shall be clean on date of substantial completion.

- 3. Protect surfaces from damage until date of substantial completion.
- 4. Replace or repair damaged work in a satisfactory manner.

**3.04 SCHEDULE**

**A. Countertops:**

- 1. Location: [\_\_\_\_\_].
- 2. Porcelain surface is adhesively joined with exposed seams.
- 3. Portfolio: [\_\_\_\_\_], Color: [\_\_\_\_\_], Finish:[\_\_\_\_\_].
  - a. Horizontal Thickness [\_\_\_\_\_].
  - b. Edge Details [\_\_\_\_\_].
  - c. Backsplash [\_\_\_\_\_].
  - d. Sidesplash [\_\_\_\_\_].
  - e. Sink [\_\_\_\_\_].

**A. Countertops with integrated Corian® Solid Surface sinks:**

- 1. Location: [\_\_\_\_\_].
- 2. Follow manufacturer’s recommendations to obtain a smooth transition between adhesively joined top and sink.
- 3. Porcelain surface is adhesively joined with exposed seams.
- 4. Portfolio: [\_\_\_\_\_], Color: [\_\_\_\_\_], Finish:[\_\_\_\_\_].
  - a. Horizontal Thickness [\_\_\_\_\_].
  - b. Edge Details [\_\_\_\_\_].
  - c. Backsplash [\_\_\_\_\_].
  - d. Sidesplash [\_\_\_\_\_].
  - e. Sink [\_\_\_\_\_].

**B. Countertops with [undermount][top mount] sinks:**

- 1. Location: [\_\_\_\_\_].
- 2. Porcelain surface is adhesively joined with exposed seams.
- 3. [Silicone adhesive is used for top mount sink and independent support (cradle) for sink is required.]
- 4. Portfolio: [\_\_\_\_\_], Color: [\_\_\_\_\_], Finish:[\_\_\_\_\_].
  - a. Horizontal Thickness [\_\_\_\_\_].
  - b. Edge Details [\_\_\_\_\_].
  - c. Backsplash [\_\_\_\_\_].
  - d. Sidesplash [\_\_\_\_\_].
  - e. Sink [\_\_\_\_\_].

**C. Countertops integrated undermount Corian® Solid Surface lavatory bowls:**

- 1. Location: [\_\_\_\_\_].
- 2. Follow manufacturer’s recommendations to obtain a smooth transition between adhesively joined top and lavatory bowl.
- 3. Porcelain surface is adhesively joined with exposed seams.
- 4. Portfolio: [\_\_\_\_\_], Color: [\_\_\_\_\_], Finish:[\_\_\_\_\_].
  - a. Horizontal Thickness [\_\_\_\_\_].

- b. Edge Details [\_\_\_\_\_].
- c. Backsplash [\_\_\_\_\_].
- d. Sidesplash [\_\_\_\_\_].
- D. Countertops with [undermount][top mount] lavatory bowls:
  - 1. Location: [\_\_\_\_\_].
  - 2. Porcelain surface is adhesively joined with exposed seams.
  - 3. Portfolio: [\_\_\_\_], Color: [\_\_\_\_], Finish:[\_\_\_\_].
    - a. Horizontal Thickness [\_\_\_\_\_].
    - b. Edge Details [\_\_\_\_\_].
    - c. Backsplash [\_\_\_\_\_].
    - d. Sidesplash [\_\_\_\_\_].
    - e. Sink [\_\_\_\_\_].
- E. Reception areas:
  - 1. Location: [\_\_\_\_\_].
  - 2. Quartz surface is adhesively joined with exposed seams.
  - 3. Portfolio: [\_\_\_\_], Color: [\_\_\_\_], Finish:[\_\_\_\_].
    - a. Horizontal Thickness [\_\_\_\_\_].
    - b. Edge Details [\_\_\_\_\_].
- F. Nurses station:
  - 1. Location: [\_\_\_\_\_].
  - 2. Porcelain surface is adhesively joined with exposed seams.
    - a. Portfolio: [\_\_\_\_], Color: [\_\_\_\_], Finish:[\_\_\_\_].
    - b. Horizontal Thickness [\_\_\_\_\_].
    - c. Edge Details [\_\_\_\_\_].
    - d. Backsplash [\_\_\_\_\_].
    - e. Sidesplash [\_\_\_\_\_].
- A. Tabletops:
  - 1. Location: [\_\_\_\_\_].
  - 2. Porcelain surface is adhesively joined with exposed seams.
  - 3. Portfolio: [\_\_\_\_], Color: [\_\_\_\_], Finish:[\_\_\_\_].
    - a. Horizontal Thickness [\_\_\_\_\_].
    - b. Edge Details [\_\_\_\_\_].
    - c. Backsplash [\_\_\_\_\_].
    - d. Sidesplash [\_\_\_\_\_].
- A. Bar tops:
  - 1. Location: [\_\_\_\_\_].
  - 2. Porcelain surface is adhesively joined with exposed seams.
  - 3. Portfolio: [\_\_\_\_], Color: [\_\_\_\_], Finish:[\_\_\_\_].
    - a. Horizontal Thickness [\_\_\_\_\_].
    - b. Edge Details [\_\_\_\_\_].
    - c. Backsplash [\_\_\_\_\_].
    - d. Sidesplash [\_\_\_\_\_].

- e. Sink [\_\_\_\_\_].
- B. Cafeteria surfaces — hot:
  - 1. Refer to Corian® Design fabrication and design recommendations.
    - a. Porcelain surface is intended to be a decorative material.
      - 1) All equipment should be independently supported by the substructure, not the porcelain surface.
  - 2. Porcelain surface is adhesively joined with exposed seams.
  - 3. Provide expansion joints in countertop as detailed on the drawings.
  - 4. Make cutouts to templates furnished by the equipment manufacturer.
  - 5. Reinforce edges and cutouts as recommended by Corian® Design.
  - 6. Provide insulation between material and adjacent hot water pans and food warmers.
  - 7. Thermally isolate hot applications from cold.
  - 8. Provide venting of cabinets as required.
  - 9. Location: [\_\_\_\_\_].
  - 10. Portfolio: [\_\_\_\_\_], Color: [\_\_\_\_\_], Finish:[\_\_\_\_\_].
    - a. Horizontal Thickness [\_\_\_\_\_].
    - b. Edge Details [\_\_\_\_\_].
    - c. Backsplash [\_\_\_\_\_].
    - d. Sidesplash [\_\_\_\_\_].
- C. Cafeteria surfaces — cold:
  - 1. Refer to manufacturer’s food service design recommendations.
  - 2. Porcelain surface is intended to be a decorative material.
    - a. All equipment should be independently supported by the substructure, not the quartz surface.
  - 3. Porcelain surface is adhesively joined with exposed seams.
  - 4. Location: [\_\_\_\_\_].
  - 5. Portfolio: [\_\_\_\_\_], Color: [\_\_\_\_\_], Finish:[\_\_\_\_\_].
    - a. Horizontal Thickness [\_\_\_\_\_].
    - b. Edge Details [\_\_\_\_\_].
    - c. Seam Width [\_\_\_\_\_].
    - d. Backsplash [\_\_\_\_\_].
    - e. Sidesplash [\_\_\_\_\_].
  - 6. Provide expansion joints in countertop as detailed on the drawings.
  - 7. Make cutouts to templates furnished by the equipment manufacturer.
  - 8. Reinforce edges and cutouts as recommended by the porcelain surface manufacturer.
  - 9. Provide insulation between material and adjacent cold surfaces.
  - 10. Thermally isolate hot applications from cold.
- D. Vanity tops with integrated Corian® Solid Surface lavatory bowls:
  - 1. Location: [\_\_\_\_\_].
  - 2. Follow manufacturer’s recommendations to obtain a smooth transition between adhesively joined top and lavatory bowl.
  - 3. Porcelain surface is adhesively joined with exposed seams.

- 4. Portfolio: [\_\_\_\_], Color: [\_\_\_\_], Finish:[\_\_\_\_].
  - a. Horizontal Thickness [\_\_\_\_].
  - b. Edge Details [\_\_\_\_].
  - c. Backsplash [\_\_\_\_].
  - d. Sidesplash [\_\_\_\_].
  - e. Sink [\_\_\_\_].
- E. Vanity tops and [undermount] [top mount] lavatory bowls:
  - 1. Location: [\_\_\_\_].
  - 2. Follow manufacturer's recommendations to obtain a smooth transition between adhesively joined top and lavatory bowl.
  - 3. Porcelain surface is adhesively joined with exposed seams.
  - 4. Portfolio: [\_\_\_\_], Color: [\_\_\_\_], Finish:[\_\_\_\_].
    - a. Horizontal Thickness [\_\_\_\_].
    - b. Edge Details [\_\_\_\_].
    - c. Backsplash [\_\_\_\_].
    - d. Sidesplash [\_\_\_\_].
    - e. Sink [\_\_\_\_].
- F. Vanity tops and [undermount] [top mount] lavatory bowls:
  - 1. Location: [\_\_\_\_].
  - 2. Porcelain surface is adhesively joined with exposed seams.
    - a. Portfolio: [\_\_\_\_], Color: [\_\_\_\_], Finish:[\_\_\_\_].
    - b. Horizontal Thickness [\_\_\_\_].
    - c. Edge Details [\_\_\_\_].
    - d. Backsplash [\_\_\_\_].
    - e. Sidesplash [\_\_\_\_].
    - f. Sink [\_\_\_\_].

**END OF SECTION**